



MAYA FAN AIR EN  
Plot No. 53 B, Industrial Area No. 1,  
Premier Square, A.B. Road,  
DEWAS - 455 001 (M.P.)

STEEL AUTHORITY OF INDIA LIMITED  
PURCHASE DEPARTMENT  
BHILAI STEEL PLANT

\*\*\*

NO. 01/BHI-05/22.1(008) 4029

Bhilai, Dated 5.12.2007

To,

M/s Maya Fan Air Engg. (P) Ltd.,  
Plot No. 53 B, Industrial Area No. 1,  
Premier Square, A.B. Road,  
DEWAS - 455 001 (M.P.)

Sub: Performance Report.

- Ref: 1. A/T No. 01/BHI-05/22.1(008)/20607068 Dated 14.2.2007.
- 2. Letter No. DGM I/C(WM)/2/5(06)/07/1836 Dated 29.11.2007.

Dear Sirs,

The performance of the Energy Efficient Statically Balanced FRP Blade Fan supplied against the above referred A/T are found satisfactory and as per the note No. 4 of A/T.

Thanking you,

*R.K. Kabalia*  
6/12/07  
(R.K. Kabalia)  
Jr. Executive (Purchase)

Parameter	Unit	4029	4030	4031	4032	4033	4034	4035
Supply Voltage	Volt	400	400	400	400	400	400	400
Motor Current	Amps	24.15	24.15	24.15	24.05	16.45	17.45	16.45
Consumed Power	kW	9.57	9.74	9.52	9.53	6.32	6.45	6.45
Power Factor		0.85	0.85	0.85	0.85	0.80	0.80	0.80
Power Saving	%					28.74		